



TIME UNIT		INSTANTANEOUS UNIT		INVERSE TIME CURRENT CURVES TO BS 142	
RATINGS (A)	GRADED TAPS (A)	SETTINGS (A)	NOTES	RELAY TYPE	CDG 13, 23, 33, 43, 53, 63
0.05 - 0.2	0.05 0.06 0.075 0.10 0.12 0.15 0.2	0.5 - 2	Standard unit type CAG13, with continuously adjustable settings.	CHARACTERISTIC	Very inverse: 1.5s at 10×I _s
0.1 - 0.4	0.1 0.12 0.15 0.2 0.24 0.3 0.4	1 - 4		STARTING CURRENT (% Setting Current)	103% to 110%
0.2 - 0.8	0.2 0.24 0.3 0.4 0.48 0.6 0.8	2 - 8		CLOSING CURRENT (% Setting Current)	120% maximum
0.25 - 1.0	0.25 0.3 0.375 0.5 0.6 0.75 1.0	2.5 - 10		FREQUENCY	50 Hz or 60 Hz
0.5 - 2.0	0.5 0.6 0.75 1.0 1.2 1.5 2.0	4 - 20		DRAWING No.	398.23.98
1.0 - 4.0	1.0 1.2 1.5 2.0 2.4 3.0 4.0	5 - 40			
1.5 - 6.0	1.5 1.8 2.25 3.0 3.6 4.5 6.0	10 - 80			
2.5 - 10.0	2.5 3.0 3.75 5.0 6.0 7.5 10.0	20 - 160			
4.0 - 16.0	4.0 4.8 6.0 8.0 9.6 12.0 16.0	40 - 200			
ALSTOM T&D Ltd Protection & Control					